



Temperature and humidity taken in the NSERL Lithography Bay (#2): Temperature (Red) is indicated on the left vertical axis and Humidity (blue) is indicated on the right hand scale. Spec is stated as Temperature = 70 F +/- 1 F and relative Humidity = 45% +/- 5%. Excursions above and below spec in this time period were due to building shutdowns for facilities work.